


WPCLF Bid Specification	 Defiance County General Health District 1300 East Second Street, Suite 100, Defiance, Ohio 43512 Phone 419-784-3818 Fax 419-782-4979	Loan Year Ending	
		Nov 30, 2017	
Date posted 04/18/2017	Date Received	Date awarded	Sanitarian

Name of Grant Applicant	Address		Township
	Carpenter Road, Defiance, OH		Adams 18
Home Phone	Cell Phone	e-mail	Funding level
			85%

Bid request for: Design Stage Installation Phase Both

Item #	Activity	Specification	Quantity	Cost
1	Septic Tank	2000 gallon, 2 compartment septic tank (or 2 1000 gallon tanks), excavation, backfill, filter, and risers to grade. Connect to existing sand filter.		
2	Inspection port	Locate outlet pipe to sand filter and install an 8-inch diameter inspection port.		
3	Abandonment	Pump 1500 g septic tank and collapse. Fill excavation to grade with appropriate fill material.		
4	Cover	Grade ground, seed and straw any disturbed areas.		
5	Eligible Miscellaneous Costs			
6	Permit	Installation permit		350.00
			Total	

Costs ineligible for funding: Sales tax, administrative costs, contractor registration fees, insurance costs, performance bond costs, abandonment of water wells, connecting home to public sewer system, sewage systems for new homes.

Eligible costs: Connections or reconnections outside home, indoor plumbing*, pumping and demolition of failing HSTS, design costs, health district installation permit fees, cost of soil scientist/evaluator, NPDES Permit fees, Site and Soil Survey, removal of trees, removal of vegetation. *Plumbing (sewer) connections must be itemized and be necessary for health district approval of the system.

Installer

Date

Phone

Ohio law requires that underground utilities be located prior to excavation. Contact the OHIO UTILITIES PROTECTION SERVICE at 811 or 1-800-362-2764

North Profile

100'

Clean-out

Underground
Cable
Tapped
1800'

Tank
Placement
11' in ID
from
house

300 sq ft
Sand Filter

septic
tank

install inspection
port

← 25' →

New 4" x 6" tile
in ditch

Carpenter
Road

